
From: EOC Water
Sent: Friday, September 1, 2017 8:33 AM
To: FEMA-NRCC-ohul; 'EOC_Water@epamail.epa.gov'
Cc: Mason, Steve
Subject: Re: Tracking of DW and WW plants operations

Hi Bill,
Here is the latest on Beaumont.
David Goldbloom-Helzner (staffing the EOC Water desk today)

On August 31, 2017, the EPA representative at the FEMA's Regional Response Coordination Center reported that the City of Beaumont is out of potable water. The drinking water system's pumps are underwater and not functional. TCEQ just gave us an short update. They are still assessing outages in Orange County, but for the Beaumont Water Plant: It's not operational now, but staff are running a line to the Nueces River near the existing intake on a temporary basis so service can be restored. By noon tomorrow they hope to be at half capacity, 10 MGD, and to full capacity of 20 MGD within 48 hours. Storage tanks are full or near full and valved off. The town is on a boil water notice. The residents are being provided bottled water and porta potties are being trucked in and set up.

On Saturday, September 2, 2017, EPA will send four additional Drinking Water/Wastewater Assessment Teams to Corpus Christi, and four Drinking Water/Wastewater Assessment Teams to Houston.

From: FEMA-NRCC-ohul
Sent: Friday, September 1, 2017 9:19:02 AM
To: 'EOC_Water@epamail.epa.gov'
Cc: Mason, Steve
Subject: Tracking of DW and WW plants operations
Hi,

This is Bill Steuteville at the NRCC ESF10 desk. I am looking for any update on tracking DW and WW facilities and, particularly, the City of Beaumont.

Thanks Bill

, NRCC ESF-10 Oil and Hazmat Unit Lead
FEMA-NRCC-ohul@fema.dhs.gov
202-212-2466 ESF 10 Desk Unit Leader